



Borough of Florham Park

111 RIDGEDALE AVENUE
FLORHAM PARK, NEW JERSEY 07932

(P): 973-410-5300

(F): 973-377-5749

www.florhamparkboro.net

Sewer Line requirements for demolition:

We may be able to provide a sketch which is for informational purposes only to aid you in the location of the line.

1. A minimum **24 hour notice** is required for the inspection of a capped sewer line by the Florham Park Sewer Utility. A sewer inspection form will be filled out when it is completed and the Building Department will be notified.
2. The FPSU is now requiring a cleanout to be installed at the place of the disconnect. The Utility requires the 4" sanitary sewer lateral cleanout to be temporarily sealed with a 4" rubber test cap located 1' foot from the right-of-way line, outside the right-of-way.
3. The location of the capped line must be clearly marked with a raised cleanout after the backfill.
4. A Re-Connection fee of \$3,829.00 payable to the Florham Park Sewerage Utility is due at the time of permits. Please provide the utility with your name and mailing address for an invoice.
5. When the sewer lateral is reconnected to the main, a re-connection inspection must be completed. A **24 hour notice** is required for the inspection by the Florham Park Sewer Utility. **In order to successfully pass the re-connection inspection, the house sewer connection diagram must be completed during or before the inspection for future cleanout reference.** It can be returned to the Florham Park Sewer Utility at PO Box 131, Florham Park, NJ 07932 or via email to sherold@fpboro.net.

Thank you.

Joseph DePasquale
Florham Park Sewerage Utility
P.O. Box 131
31 Vreeland Road
Florham Park, NJ 07932